

**Government Of Maharashtra Public Health Department**

**DISTRICT PUBLIC HEALTH LABORATORY, AMRAVATI.**

E-mail ID: [dphlamt@gmail.com](mailto:dphlamt@gmail.com) Phone No. 0721 - 2660537

**REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER FOR DRINKING PURPOSE**

To :- Head Master, P. R. Pote Patil International School, Shree Gajanan Township, Amravati.

Letter NO & Date : - 19.12.2024

Lab Ref no.:- 727

Date of Collection: - 19/12/2024

Date of Receipt: - 19/12/2024

Date of Examination: -19/12/2024

| S<br>·<br>N<br>· | Particular Of Samples                            | Results Of Examination |                |        | Remarks |
|------------------|--------------------------------------------------|------------------------|----------------|--------|---------|
|                  |                                                  | Bacteria Per 100ML     |                |        |         |
|                  |                                                  | Coli forms             | Thermotolarent | E.coli |         |
| 1                | Tap Water, P. R. Pote Patil International School | 0                      | -              | -      | Potable |

**Note :**Contaminated water sample should be properly chlorinated & rested for Bacteriological test and after confirmation, can be used for drinking Purpose.

**Note :-1.** It is presumed that the above water sample is collected by responsible person and from the same source mention in your letter.


**2.** This Report is restricted only for the sample submitted to this Laboratory.


**HEALTH SERVICES**


No./dphl/Amt/Bact./ L.R 727/4238/2024

District Public Health Laboratory, Amravati

Dated :- 24/12/2024

  
Junior Scientific Officer  
District Public Health Laboratory,  
AMRAVATI

  
Principal  
P.R.Pote Patil International School  
Amravati.

  
Secretary  
P.R. Pote (Patil) Edun. & Welfare Trust  
Amravati.